



IMPORTANT INFORMATION

RE: Explosion / Water Resistant Equipment

Some equipment does not have a UL, CSA, or NEMA rating

G.A.L. has been producing equipment for many years that has been generally referred to as Explosion Resistant or Water Resistant. With no representation of approval by any testing organization, this equipment has been well accepted and performed per expectation in what has been described as a water resistant or explosion resistant environment. Please see the table below that summarizes the approval level of GAL's water and explosion resistant products. Please make sure that the Authority Having Jurisdiction / Consultant / End User understands that some of this equipment does not bear any label / special application label.

Equipment	NEMA rated	UL listed	CSA certified
MOWH interlock	NO	NO	NO
MOXH interlock	YES (NEMA 7, Class 1, Group D)	YES	NO
WP interlock	YES (NEMA 4)	NO	YES
WX interlock	YES (NEMA 7 & 9, Class 1, Group D and Class 2, Groups E, F and G)	YES	YES
MOVFRW operator	NO	NO	NO
MOX operator	NO	NO	NO
GW gate switch	NO	NO	NO
GX gate switch	NO	NO	NO